



Product Service

Compliance Document

No. D 093675 0030 Rev. 03

Holder of Certificate: **GCL System Integration Technology Co., Ltd.**
Jianghai Economic Zone, Nanqiao Town
Fengxian District
201406 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

Model(s): GCL-M12/60GDFxxx (xxx=575-610 in step of 5W)
GCL-M12/66GDFxxx (xxx=630-675 in step of 5W)
GCL-M10/72GDFxxx (xxx=520-555 in step of 5W)
GCL-M10/60GDFxxx (xxx=450-460 in step of 5W)
GCL-M10/54GDFxxx (xxx=390-415 in step of 5W)
GCL-NT12/60GDFxxx (xxx=600-620 in step of 5W)
GCL-NT12/66GDFxxx (xxx=660-685 in step of 5W)
GCL-NT10/72GDFxxx (xxx=550-575 in step of 5W)
GCL-NT10/60GDFxxx (xxx=460-475 in step of 5W)
GCL-NT10/54GDFxxx (xxx=415-430 in step of 5W)
xxx is standing for rated output power at STC

Parameters: Safety Class: Class II
Max. System Voltage: 1500V DC
Construction: Framed, with Junction box, cable and connector.
PID test condition: ± 1500 V, 192 Hours, 85 °C, 85 % RH
PID testing method is according to IEC TS 62804-1:2015

Tested according to: IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
PPP 58042B:2015

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062124008-03

Date, 2023-05-11

(Zhulin Zhang)